QC ABSTRACT

NAME OF WORK: Improvements to Toilets Works in Ward No.8

SL NO	Item Of Work	Name of Test	Frequency of Test/Quantity	Executed Quantity	Number of Tests Required	Number of Tests Conducted
		Materials				
1	Cement	Fineness by dry sieving	One Test		1	1
		Finess by Air permeablity method	One Test		1	1
		Density	One Test		1	1
		Standard Consistency	One Test		1	1
		Initial Setting time	One Test		1	1
		Final Setting time	One Test		1	1
		Soundness (Le Chatelier's Method)	One Test		1	1
		Compressive Strength	One Test		1	1
2	Fine aggregate	SIEVE ANALYSIS	One Test		1	1
		Water Absorption	One Test		1	1
		Specific Gravity	One Test		1	1
		Material finer than 75 micron	One Test		1	1
3	CERAMIC TILES	MEASUREMENTS OF LENGTH, WIDTH AND THICKNESS	One Test		1	1
		MODULUS OF RUPTURE AND BREAKING STRENGTH	One Test		1	1
4	Mortar Sand	Water Absorption	One Test		1	1
		Specific Gravity	One Test		1	1
		Material finer than 75 micron	One Test		1	1
		Compacted Bulk Density	One Test		1	1
		Loose Bulk Density	One Test		1	1
		SIEVE ANALYSIS	One Test		1	1
5	Plaster Sand	Water Absorption	One Test		1	1
		Specific Gravity	One Test		1	1
		Material finer than 75 micron	One Test		1	1
		SIEVE ANALYSIS	One Test		1	1

Assistant Executive Engineer
Kodigehalli Sub Division
BBMP, Bangalore

Format No: CP/TF/01

TEST REPORT OF PHYSICAL PROPERTIES OF CEMENT - 53 Grade

Lab ID	:	**CP-2020-12-02-05** **Date: 03-08-20**
Customer	:	Assistant Executive Engineer, Kodigehalli Sub Division, BBMP, Bangalore.
Address	:	Kodigehalli Sub Division, BBMP, Bangalore.
Project Name	:	Improvements to Toilets Works in Ward No.8
Agency	:	Sri.Srikanth K.S, Aakar Construction, #168, AMCO Layout Near, Godwin School, Sahakarnagara Post, Bangalore-92
Customer's Reference	:	BBMP/EE/BTP/WO/66/2020-21
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	31-07-20
Sample Type	:	Birla Super 53grade
Reference to BIS codes	:	IS 12269 : 2013, 53 Grade Ordinary Portland cement Specification , IS 4031 (Part 1,2 3,4,5, 6,11):1988 IS 4031 Part 1 DETERMINATION OF FINENESS BY DRY SIEVING, Clause 4.4 IS 4031 Part 2, Determination of Fineness by Blaine Air Permeability Method, Clause 5 IS 4031 Part 3, Determination of Soundness, Clause 5,Clause 6 IS 4031 Part 4, Determination of Consistency of Standard Cement Paste, Clause 5 IS 4031 Part 5, Determination of Initial & Final Setting Time, Clause 5 IS 4031 Part 11,DETERMINATION OF DENSITY , Clause 6
Date of test	:	01-08-20
Environmental Conditions during test	:	Temperature: 26°C Humidity: 72%

Sl.No.	Physical properties	Results	Requirement as per IS 12269: 2013
1	Fineness by dry sieving (%)	2.42	_
2	Finess by Air permeablity method (m^2/kg,Min)	255.4	225m^2/kg, Min
3	Density (gm/cc)	3.12	_
4	Standard Consistency (%)	28.5%	Not specified
5	Initial Setting time	170 minutes	Not less than 30 minutes
6	Final Setting time	265 minutes	Not more than 600 minutes
7	Soundness (Le Chatelier's Method)	1.3mm	Not more than 10 mm

* The results obtained are satisfactory as per standard requirements.

Note:

The results pertain to the samples received and tested.

All information furnished by Customer/Representative

Any correction in the report will make this report invalid

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL Pro Sig. Date BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Kodigehalli Sub Division
BBMP, Bangalore

****End of Report****

Format No: CP/TF/01

TEST REPORT OF PHYSICAL PROPERTIES OF CEMENT - 53 Grade

Lab ID	:	**CP-2020-12-02-05** **Date: 29-08-20**
Customer	:	Assistant Executive Engineer, Kodigehalli Sub Division, BBMP, Bangalore.
Address	:	Kodigehalli Sub Division, BBMP, Bangalore.
Project Name	:	Improvements to Toilets Works in Ward No.8
Agency	:	Sri.Srikanth K.S, Aakar Construction, #168, AMCO Layout Near, Godwin School, Sahakarnagara Post, Bangalore-92
Customer's Reference	:	BBMP/EE/BTP/WO/66/2020-21
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	31-07-20
Sample Type	:	Birla Super 53grade
Reference to BIS codes	:	IS 12269 : 2013, 53 Grade Ordinary Portland cement Specification , IS 4031 Part 4, Determination of Consistency of Standard Cement Paste, Clause 5 IS 4031 Part 6, Determination of Compressive Strength, Clause 6
Date of test	:	01-08-20
Environmental Conditions during test	:	Temperature: 26°C Humidity: 72%

Compressive Strength

Sl.No.	Physical properties	Results	Requirement as per IS 12269: 2013
1	3 Days	28.0N/mm^2	Not less than 27 N/mm^2
2	7 Days	39.5N/mm^2	Not less than 37 N/mm^2
3	28 Days	58.5N/mm^2	Not less than 53 N/mm^2

* The results obtained are satisfactory as per standard requirements.

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

Assistant Executive Engineer
Kodigehalli Sub Division
BBMP, Bangalore

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

Format No: CP/TF/01

TEST REPORT OF FINE AGGREGATE

Lab ID : **CP-2020-12-02-05** **Date: 03-08-20**

Customer : Assistant Executive Engineer, Kodigehalli Sub Division, BBMP, Bangalore.

Address : Kodigehalli Sub Division, BBMP, Bangalore.

Project Name : Improvements to Toilets Works in Ward No.8

Agency : Sri.Srikanth K.S, Aakar Construction, #168, AMCO Layout Near, Godwin School, Sahakarnagara Post, Bangalore-92

Customer's Reference : BBMP/EE/BTP/WO/66/2020-21

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 31-07-20

Sample Type : Fine Aggregate

Reference to BIS codes : IS 383 : 2016 (Specification for Coarse and fine Aggregates)
IS: 2386 :1963(Part - 1, 3) RA2012
IS 2386 Part 1: Particle Size and Shape
IS 2386 Part 3: Specific gravity, Density, Voids,Water Absorption

Date of test : 31-07-20

Total weight taken : 1000 grams

Sl.no	Sieve Size	Weight Retained (gms)	Cumulative Weight Retained (gms)	% Cumulative Weight Retained	% Passing	Requirement as per IS 383:2016			
						Grading Zone I	Grading Zone II	Grading Zone III	Grading Zone IV
1	10 mm	0	0	0.0	100.0	100	100	100	100
2	4.75 mm	28	28	2.8	97.2	90-100	90-100	90-100	95-100
3	2.36 mm	54	82	8.2	91.8	60-95	75-100	85-100	95-100
4	1.18 mm	238	320	32.0	68.0	30-70	55-90	75-100	90-100
5	600 micron	207	527	52.7	47.3	15-34	35-59	60-79	80-100
6	300 micron	202	729	72.9	27.1	5-20	8-30	12-40	15-50
7	150 micron	190	919	91.9	8.1	0-10	0-10	0-10	0-15
8	Pan	81	1000	100.0	0.0	---	---	---	---

Result :The tested Sample Conforms to Grading Zone II

Assistant Executive Engineer
Kodigehalli Sub Division
BBMP, Bangalore

CIVIL PRO BANGALORE Sig. Date

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

TEST REPORT OF FINE AGGREGATE

Lab ID : **CP-2020-12-02-05**

Date: 03-08-20

PHYSICAL PROPERTIES

Sl.no	Tests	Result	Requirements as per IS 383:2016
1	Water Absorption(%)	1.4	–
2	Specific Gravity	2.58	–
3	Material finer than 75 micron(%)	6.8	Uncrushed fine Aggregate Max 3%, Crushed Fine aggregate Max 15%, Mixed Fine aggregate Max 12%, Manufactured Fine aggregate Max 10%

* The results obtained are satisfactory as per standard requirements.

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL Pro Sig Date BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Kodigehalli Sub Division
BBMP, Bangalore

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Format No: CP/TF/2017

TEST REPORT FOR SAND MASONRY MORTARS

Lab ID : **CP-2020-12-02-05** **Date: 20-08-20**

Customer : Assistant Executive Engineer, Kodigehalli Sub Division, BBMP, Bangalore.

Address : Kodigehalli Sub Division, BBMP, Bangalore.

Project Name : Improvements to Toilets Works in Ward No.8

Agency : Sri.Srikanth K.S, Aakar Construction, #168, AMCO Layout Near, Godwin School, Sahakarnagara Post, Bangalore-92

Customer's Reference : BBMP/EE/BTP/WO/66/2020-21

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 17-08-20

Sample Type : Fine Aggregate, M.Sand for Mortar

Reference to BIS codes :
IS 383 : 2016 (Specification for Coarse and fine Aggregates)
IS: 2116-1980 (RA-2007) (Specification for Sand for Masonry Mortars)
IS: 2386 :1963(Part - 1, 3) RA2012
IS 2386 Part 1: Particle Size and Shape
IS 2386 Part 3: Specific gravity, Density, Voids,Water Absorption

Date of test : 17-08-20

Total weight taken : 1000 grams

Sl.no	Sieve Size	Weight Retained (gms)	Cumulative Weight Retained (gms)	% Cumulative Weight Retained	% Passing	Requirement as per IS: 2116-1980 (RA-2007)
1	4.75 mm	0	0	0	100	100
2	2.36 mm	85	85	8.5	91.5	90-100
3	1.18 mm	200	285	28.5	71.5	70-100
4	600 micron	146	431	43.1	56.9	40-100
5	300 micron	116.5	547.5	54.8	45.3	5-70
6	150 micron	412.5	960	96.0	4.0	0-15
7	Pan	40	1000	100.0	0.0	0

Assistant Executive Engineer
Kodigehalli Sub Division
BBMP, Bangalore

CIVIL PRO Sig..... Date..... BANGALORE

TEST REPORT FOR SAND MASONRY MORTARS

Lab ID : **CP-2020-12-02-05** **Date: 20-08-20**

PHYSICAL PROPERTIES

Sl.no	Tests	Result	Requirements as per IS 383:2016
1	Water Absorption(%)	3.18	–
2	Specific Gravity	2.51	–
3	Material finer than 75 micron(%)	12.2	Crushed Fine aggregate Max 15%
4	*Compacted Bulk Density (Kg/litre)	1.90	–
5	*Loose Bulk Density (Kg/litre)	1.73	–

* The results obtained are satisfactory as per standard requirements.

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Kodigehalli Sub Division
BBMP, Bangalore

****End of Report****

Format No: CP/TF/2017

TEST REPORT FOR PLASTER SAND

Lab ID	:	**CP-2020-12-02-05** **Date: 21-08-20**
Customer	:	Assistant Executive Engineer, Kodigehalli Sub Division, BBMP, Bangalore.
Address	:	Kodigehalli Sub Division, BBMP, Bangalore.
Project Name	:	Improvements to Toilets Works in Ward No.8
Agency	:	Sri.Srikanth K.S, Aakar Construction, #168, AMCO Layout Near, Godwin School, Sahakarnagara Post, Bangalore-92
Customer's Reference	:	BBMP/EE/BTP/WO/66/2020-21
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	17-08-20
Sample Type	:	Plaster Sand
Reference to BIS codes	:	IS: 383 : 2016 (Specification for Coarse and fine Aggregates) IS1542:1992 (Sand for Plaster - Specification) IS: 2386 :1963(Part - 1, 3) RA2012 IS 2386 Part 1: Particle Size and Shape IS 2386 Part 3: Specific gravity, Density, Voids,Water Absorption
Date of test	:	17-08-20
Total weight taken	:	1000 grams

Sl.no	Sieve Size	Weight Retained (gms)	Cumulative Weight Retained (gms)	% Cumulative Weight Retained	% Passing	Requirement as per IS 1542:1992
1	10 mm	0	0	0	100	100
2	4.75 mm	35	35	3.5	96.5	95-100
3	2.36 mm	15	50	5	95	95-100
4	1.18 mm	50	100	10	90	90-100
5	600 micron	100	200	20	80	80-100
6	300 micron	215	415	41.5	58.5	20-65
7	150 micron	500	915	91.5	8.5	0-15
8	Pan	85	1000	100	0	---

Assistant Executive Engineer
Kodigehalli Sub Division
BBMP, Bangalore

CIVIL PRO Sig. Date. BANGALORE

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

TEST REPORT OF FINE AGGREGATE

Lab ID : **CP-2020-12-02-05** **Date: 21-08-20**

PHYSICAL PROPERTIES

Sl.no	Tests	Result	Requirements as per IS 383:2016
1	Water Absorption(%)	1.8	–
2	Specific Gravity	2.56	–
3	Material finer than 75 micron(%)	8.5	Uncrushed fine Aggregate Max 3%, Crushed Fine aggregate Max 15%, Mixed Fine aggregate Max 12%, Manufactured Fine aggregate Max 10%

* The results obtained are satisfactory as per standard requirements.

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL Pro Sig. Date BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Kodigehalli Sub Division
BBMP, Bangalore

****End of Report****

TEST REPORT OF CERAMIC TILES

Lab ID	:	**CP-2020-12-02-05** **Date: 14-08-20**
Customer	:	Assistant Executive Engineer, Kodigehalli Sub Division, BBMP, Bangalore.
Address	:	Kodigehalli Sub Division, BBMP, Bangalore.
Project Name	:	Improvements to Toilets Works in Ward No.8
Agency	:	Sri.Srikanth K.S, Aakar Construction, #168, AMCO Layout Near, Godwin School, Sahakarnagara Post, Bangalore-92
Customer's Reference	:	BBMP/EE/BTP/WO/66/2020-21
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	08-08-20
Sample Type/ Size	:	Ceramic tiles (300X300)mm
Reference to BIS codes	:	IS 13630 (part 1) : 2006, IS 15622:2006
Date of test	:	08-08-20

MEASUREMENTS OF LENGTH, WIDTH AND THICKNESS

Number Of Specimen	Length measured at position 5mm from the corner		Breadth measured at position 5mm from the corner		Thickness measured at thickest part, 4 diagonal segment			
	1	2	1	2	1	2	3	4
1	300	300	300	300	6.04	6.01	6.08	6.04
2	300	300	300	300	6.01	6.07	6.01	6.01
3	300	300	300	300	6.03	6.05	6.06	6.03
4	300	300	300	300	6.06	6.05	6.08	6.06
5	300	300	300	300	6.08	6.06	6.05	6.08
6	300	300	300	300	6.03	6.07	6.07	6.07
7	300	300	300	300	6.08	6.05	6.08	6.07
8	300	300	300	300	6.02	6.05	6.04	6.05
9	300	300	300	300	6.04	6.04	6.02	6.04
10	300	300	300	300	6.04	6.01	6.05	6.04
Average	**300**		**300**		**6.05**			

Assistant Executive Engineer
Kodigehalli Sub Division
BBMP, Bangalore

CIVIL PRO Sig..... Date..... BANGALORE

TEST REPORT OF CERAMIC TILES

WATER ABSORPTION

Sl.no	Weight of oven dry sample	Saturated weight of sample	Water absorption by mass	Average value of water absorption
1	1406	1455	3.49	2.85
2	1424	1464	2.81	
3	1464	1498	2.32	
4	1408	1454	3.27	
5	1434	1468	2.37	

MODULUS OF RUPTURE AND BREAKING STRENGTH

Sl.No

Sl.No.	Dimension (mm)			Wet Transverse Strength	Average
	L	B	T	(N/mm^2)	(N/mm^2)
1	300	300	6.04	14.8	14.66
2	300	300	6.06	14.2	
3	300	300	6.02	14.9	
4	300	300	6.06	14.8	
5	300	300	6.05	14.6	

* The results obtained are satisfactory as per standard requirements.

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL Pro Sig..... Date.....

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Assistant Executive Engineer
Kodigehalli Sub Division
BBMP, Bangalore

End of Report

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com